

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001



No.F.6/DFS/MS/School/2025/SZ/1045

Dated: 21/08/2025

FIRE SAFETY CERTIFICATE

Certified that the **Mata Gujri Public School**, at Gurdwara Singh Sabha (opp. C Block), Greater Kailash -I, New Delhi-110048 comprised of 03 Blocks, Block 01- G+3, Block 02- G+1, Block 03- B+G+2 upper floors owned/occupied by Mata Gujri Public School, was issued Fire Safety Certificate by this department vide letter no. F6/MS/DFS/School/2022/SZ/821 Dated 29-07-2022. The premises was re-inspected by officer concerned by this department on 04/08/2025 in the presence of Mrs. Daljeet Kaur Bhandari of the school and observed that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular no 262-362 dated 17/01/2005 and that the building is fit for occupancy class "**Educational**" Group-B (School) as above with effect from 21/08/2025 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of conditions mentioned below.

Issued 21/08/2025 at New Delhi by


21/08/2025
(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE


Copy to: -

1. The Principal, Mata Gujri Public School, Gurdwara Singh Sabha (opp. C Block, Greater Kailash -I, New Delhi-110048
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The basement shall be used as per the provisions of BBL/NBC Part IV.
5. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.