



**MUNICIPAL CORPORATION OF DELHI
OFFICE OF THE DEPUTY HEALTH OFFICER
PUBLIC HEALTH DEPARTMENT
GREEN PARK, AURBINDO MARG,
NEW DELHI-110016**



NO. DHO/SZ/MCD/2026/D-2071

Dated: 18.3.26


SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Sh. S anjeev Kumar, Public Health Inspector from Public Health Department, South Zone inspected Mata Gujri Public School located at Gurdwara Singh Sabha, (Opposite C Block), Greater Kailash-I, New Delhi-110048.

It was found that the School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus.

The above certificate is valid for one year from date of issue.

If Building Department or any other Government Agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/ revoked without any further intimation in this regard.



**Deputy Health Officer
South Zone
Dy. Health Officer
South Zone MCD**

Copy to: -

- The Principal
Mata Gujri Public School
Gurdwara Singh Sabha,
(Opposite C Block),
Greater Kailash-I, New Delhi- 110048.
- Office Copy

TEST REPORT

ULR-TC143242600001358F
Report Issue Date : 24-Feb-2026
Reference Number : 003:W:26:02:00651
Report Number : EQNX:003:W:26:02:00651



NABL Scope



TC-14324

Information Provided by Customer

Client Name : Mata Gujri Public School Sampling Location : 1st Floor, Class Room No. 205 Area
Address : Opposite Block C, Greater Kailash Part 1, New Delhi, Delhi, India - 110048. Sample Sub Group : Drinking Water
Sample Name : Drinking Water
Contact Person : Gurvinder Singh

Particulars of Sample Analysed

Sampling Protocol : SOP-MCB-39-00,SOP-ENV-01-02 Sample Drawn by : Equinox Labs - Rahul Kumar

Quantity & Condition : 1 Ltr. water in a white HDPE bottle and 250ml water in a sterilized plastic bottle. Both bottles are intact without any leaks

Date of Sampling	Date of Receipt	Start Date of Analysis	End Date of Analysis
17-Feb-2026	18-Feb-2026	18-Feb-2026	20-Feb-2026

----- Result of Analysis -----

Discipline : Biological Group : Water

Sr.No	Parameters	Units	Methods	Results of Analysis	Limit
1	Standard Plate Count	cfu/ml	IS 1622	6.9x(10) ¹	Not Specified
2	Coliform	/100ml	IS 15185	Not-Detected	Not Detectable
3	E. coli	/100ml	IS 15185	Not-Detected	Not Detectable

Discipline : Chemical Group : Water

Sr.No	Parameters	Units	Methods	Results of Analysis	Limit
1	Turbidity	NTU	IS 3025 (Part 10)	<0.5	Max 1
2	Colour	CU	IS 3025 (Part 4)	<1.0	Max 5
3	pH - Value at 25°C	-	IS 3025 (Part 11)	7.04	6.5-8.5
4	Taste	-	IS 3025 (Part 8)	Agreeable	Agreeable
5	Odour	-	IS 3025 (Part 5)	Agreeable	Agreeable

TEST REPORT

ULR-TC143242600001358F
Report Issue Date : 24-Feb-2026
Reference Number : 003:W:26:02:00651
Report Number : EQNX:003:W:26:02:00651



NABL Scope



TC-14324

Sr.No	Parameters	Units	Methods	Results of Analysis	Limit
6	Electrical Conductivity at 25°C	µS/cm	IS 3025 (Part 14)	170	Not Specified
7	Total Dissolved Solids at 180°C	mg/l	IS 3025 (Part 16)	110	Max 500
8	Total Alkalinity as CaCO ₃	mg/l	IS 3025 (Part 23)	11.4	Max 200
9	Phenolphthalein Alkalinity as CaCO ₃	mg/l	IS 3025 (Part 23)	<1.0	Not Specified
10	Total Hardness as CaCO ₃	mg/l	IS 3025 (Part 21)	34.56	Max 200
11	Chloride as Cl	mg/l	IS 3025 (Part 32)	9.78	Max 250
12	Calcium as Ca	mg/l	IS 3025 (Part 40)	7.79	Max 75
13	Magnesium as Mg	mg/l	IS 3025 (Part 46)	3.68	Max 30
14	Sulphate as SO ₄	mg/l	IS 3025 (Part 24) Section 1	<1.0	Max 200
15	Reactive Silica	mg/l	IS 3025 (Part 35)	<1.0	Not Specified

Remark : 1. The sample conforms to IS 10500 : 2012 (Acceptable limits) for the parameters tested.

Naveen Chaudhary
Sr. Microbiologist - Microbiology
(Reviewed & Authorised By)

Pragati Singh
Sr. Chemist - Chemistry
(Reviewed & Authorised By)

Note:

- This Report is Valid for the tested sample only
- Test report shall not be reproduced except in full & with written approval of Equinox Labs Private Limited.
- This report should not be used for advertisement / judicial purpose.
- The information provided by customer can affect the validity of results



Download Report

----- End Of Report -----

Your Testing and Auditing Partner

Testing Lab Address : Equinox Labs Private
Limited F-296, Sector 63, Noida,
GAutambuddha Nagar,201301

TEST REPORT

ULR-TC143242600001358F
Report Issue Date : 24-Feb-2026
Reference Number : 003:W:26:02:00651
Report Number : EQNX:003:W:26:02:00651



NABL Scope



TC-14324

